## 884037558/16 | CS44Z3 WHT C6A 4/23 F/UTP RL 500M



CS44Z3 Category 6A, F/UTP Cable, low smoke zero halogen, white jacket, 4 pair count, 164Oft (500 m) length reel

## **Product Classification**

Regional Availability

Asia | Australia/New Zealand | Latin America

Portfolio NETCONNECT®

Product Type Twisted pair cable

**Product Series** 640 Series

General Specifications

ANSI/TIA Category 6A

Cable Component Type Horizontal

Cable TypeF/UTP (shielded)

Conductor Type, singles Solid
Conductors, quantity 8

Jacket Color White

Pairs, quantity 4

Transmission Standards ANSI/TIA-568.2-D | CENELEC EN 50288-6-1 | ISO/IEC 11801 Class EA

**Dimensions** 

 Cable Length
 500 m | 1,640.42 ft

 Diameter Over Jacket, nominal
 7.595 mm | 0.299 in

Conductor Gauge, singles 23 AWG

**Electrical Specifications** 

Nominal Velocity of Propagation (NVP) 69% Operating Voltage, maximum 80 V

**Remote Powering** Fully complies with the recommendations set forth by IEEE 802.3bt (Type 4) for the

safe delivery of power over LAN cable when installed according to ISO/IEC 14763-2,

CENELEC EN 50174-1, CENELEC EN 50174-2 or TIA TSB-184-A

Segregation Class

Material Specifications



## 884037558/16 | CS44Z3 WHT C6A 4/23 F/UTP RL 500M

Conductor MaterialBare copperInsulation MaterialPolyolefin

Jacket Material Low Smoke Zero Halogen (LSZH)

Shield (Tape) Material Aluminum/Polyester

Mechanical Specifications

Pulling Tension, maximum 11.34 kg | 25 lb

**Environmental Specifications** 

**Operating Temperature**  $-20 \,^{\circ}\text{C} \text{ to } +75 \,^{\circ}\text{C} \, (-4 \,^{\circ}\text{F to } +167 \,^{\circ}\text{F})$ 

Acid Gas Test Method IEC 60754-2

**Temperature Rating, UL** 75 °C | 167 °F

Flame Test Method IEC 60332-3-22

Smoke Test Method IEC 61034-2

Packaging and Weights

Packaging Type Reel

Regulatory Compliance/Certifications

Agency Classification

CHINA-ROHS Below maximum concentration value

REACH-SVHC Compliant as per SVHC revision on www.commscope.com/ProductCompliance

ROHS Compliant UK-ROHS Compliant



